

PONDICHERY UNIVERSITY
ELECTRICAL WING

V.MOUROUGAVELOU
ASSISTANT ENGINEER(E)

Ref: PU/ELW/UG cable/13-14/

R.V. NAGAR, KALAPET
PUDUCHERRY 14.

10/03/2014

To


Sir,

Sub: Rerouting of 400 sq.mm UG cable at library source from new substation-X in Pondicherry University - Reg.

Your quotation is hereby invited in sealed cover for "Rerouting of 400 sq.mm UG cable at library source from new substation-X in Pondicherry University" as mentioned in the schedule enclosed. The sealed quotations have to be placed in the Tender box kept in the Reception Counter at Administrative block on or before 19/03/2014 at 3.00pm and it will be opened on the same day at 3.30Pm.


Assistant Engineer(E)

10/3/14.



PONDICHERRY UNIVERSITY
ELECTRICAL WING

Scheduled of work

Name of the Work: Rerouting of 400 sq.mm UG cable at Library source from new substation -X in Pondicherry University.

Sl.No	Description of Item	Qty.	Unit	Rate	Amount
1.	Laying of one number PVC insulated and PVC sheathed/XLPE aluminium conductor cable of 1.1 KV grade of following size direct in ground including excavation, river sand cushioning, protective covering and refilling the trench etc as required. (Manual excavation.) a. Above 185 sq. mm. and upto 400 sq.mm.	20 mtr	mtr		
2.	Laying of one number PVC insulated and PVC sheathed/XLPE power cable of 1.1KV grade of following size in the existing RCC/HUNE/METAL pipe as required. a. Above 185 sq.mm and upto 400 sq.mm.	30 mtr	mtr		
3.	Excavation along the existing 400 sq.mm. UG cable removing the cable from the trench and refilling the trench and shifting the cable to Substation-X. (Manual Excavation.)	20 mtr	mtr		
4.	Supplying and making end termination with brass compression gland and aluminium lugs of following size of PVC insulated and PVC sheathed/XLPE aluminium conductor cable of 1.1KV grade as required. a. 3.5 x 400 sq.mm.	2 nos.	Each		
				TOTAL	

Terms & Conditions:

1. The work shall be carried out strictly in accordance with CPWD General Specifications for the Electrical works as amended up to date.
2. Prior approval of the Engineer in charge is required for all the materials to be used on works. Non- standard quality materials shall not be acceptable.
3. Bad workmanship shall not be accepted. Such work is liable for rejection and shall be rectified by the contractor at his own risk and cost.
4. Payment will be arranged after satisfactory completion of the work.
5. Amount will be arrived on the actual works done basis.
6. The work should be carried out immediately on receipts of this work order.
7. The rate for each item of work to be quoted in the enclosed schedule of work format only otherwise, the quotation in any other format is considered as invalid quotation.
8. The work should be completed within 7 days from the date of issue of the work order.

Name and signature of the Firm/
Agencies/Contractor with Seal

ASSISTANT ENGINEER(E)