

**PONDICHERRY UNIVERSITY
ELECTRICAL WING**

SCHEDULE OF WORK

Name of Work: Supplying, installing, testing and commissioning of package air conditioning plants for TIMS Laboratory to the newly constructed Earth Science Department at Pondicherry University Campus.

S. No.	Description of Item	Qty	Unit	Rate	Amount
1.	<p>Supplying, installation, testing and commissioning of floor mounted made with CRCA/GI sheet powder coated panels of 11 ton capacity, twin circuit package air conditioner comprising of the following:</p> <p>a) Scroll type hermetically sealed compressors suitable for operation with R-22 refrigerant on 380-420 volts, 3 phase, 50Hz Alternate supply with internal over load protection.</p> <p>b) Air-cooled condenser powder coated with inner grooved copper tubes, hydraulically bonded to corrugated, slit aluminium anti corrosion coated blue fins, propeller type fan and suitable motor, necessary release valve, base supports, rubber pads and base for outdoor use.</p> <p>c) Indoor unit(evaporator) with inner grooved copper tube, hydraulically bonded to corrugated, slit aluminium fins, statically & dynamically balanced centrifugal fans, suitable motor, and thermostatic expansion valve.</p> <p>d) Filter & drier, air filters, LP, HP pressure cut outs, thermostat.</p> <p>e) Control panel fixed indoor unit with micro processor based control with temperature control, compressor ON/OFF, starters for main compressor motor, condenser motor, contactors, time delay, single phasing preventor, phase reversal protections, digital display for voltage, current, temperature cut off, self diagnosis function for faults, partial load operation with memory back up, auto restart after power failure, programmable timer with necessary cabling.</p> <p>f) Supply and charging the required quantity of refrigerant 22 and compressor</p>	1	Each		

	oil, leak testing, vaccumizing the entire system as required. Make: Blue Star/Carrier/LG/ETA /Voltas				
2.	Supplying, installing, testing and commissioning of suitable capacity dehumidifying electrical strip heaters to maintain 45-50% humidity in the enclosed space and automatic dehumidifying control as required.	LS	1 set		
3.	Hard drawn copper piping of suitable size connecting refrigerant circuits both suction & discharge sides, control cable, earthing etc., between indoor and outdoor unit. (Both suction and discharge line will be taken as single unit for measurement purpose).	50 mtr	mtr		
4.	Supplying, installation of MS Callar damper with canvass cover to connect the AC plant outlet and duct/plenum as required.	1	Each		
5.	Supply and installation of GI ducting of 20 G with suitable acoustical insulation for plenum including anchor fasteners and supporting angles as required.	12	Sq.mt		
6.	Supplying and installation of 18" diameter Spiral ducting made of 24 SWG GI steel with powder coated painting including anchor fasteners and supporting angles etc., as required.	23	Sq.mt		
7.	Supplying, installation of powder coated coated Aluminium Grill with sufficient louvers to be fixed on spiral ducting.	6	Each		
8.	Fire damper with control from fire alarm system.	3	Each		
9.	Minor civil works for ducting whole, mounting out door units and drawing copper pipe on wall including supply of mounting steel angles to fix out door unit wherever necessary as per site condition.	2	Each		
		TOTAL			